R. O. File No. 472/937

Collection No.

19

11.7.47 Singapore Residency

(40)

Pros. Serial Nos. 1 — 19

(P-50) 81, 819

Petroleum Licences

Subject.

11/3 Lubs

Previous References.

Later References.

D Dis 81/38

1 A

26/7/65

NOTES AND PRECIS.

(2)

D.Nos.5155 S.N.5

D.No.5185 S.N.6

The Bangalore Petroleum Rules are in force in the C & M Station and not the British Indian Petroleum Rules of 1937 referred to by the Chief Inspector of Explosives, Calcutta. Until fresh rules are framed for the Station on the lines of the latter we have to follow the local rules. This may be pointed out to the Chief Inspector of Explosives and he may not continue to be asked whether special licences may be granted by Residency under rule 6, Chapter IV, Part II of the Bangalore Petroleum Rules.

Draft submitted for approval.

30.5.37

S.N.7 Issue

D.No.5400 S.N.8

D.No.5481 S.N.9

Please see S.N.7

Draft submitted. After issue, the file may be sent up to the C. of P. who may like to see S.N. 5 & 6.

S.N.10 Issue 8.6.37

To: The Commissioner of Police

O.O.No. 5781 dated 10.6.1937.

The Petroleum Rules, 1937, which have since been received, supersede Bangalore Petroleum Rules, 1909. The authority for granting licenses for all petrol pump outfits is the Chief Inspector of Explosives in India, Calcutta, since 30—3—1937, the date of commencement of the new Rules

In this connection a reference is invited to this office letter No. 10/Pet/37 dated 15-6-37, sent through the Dt. Magte.,

OFFICE OF THE RESIDENT IN MYSORE
BANGALORE.
17 JUNE 1937
Regd. No. 5995
File No.

To

The Asst. Secy., to the Hon'ble the Resident in Mysore
Bangalore.

D.No.5995

S.N.5 to 7
c.p. 10-12

Please see S.N.5 to 7 and paras 3 to 6 of these notes. Reply to S.N.7 from the Chief Inspector of Explosives may be awaited.

(41)

D.No.6842 S.N.11

Please see S.N.5 & 6 (p.10 & 13)

As recommended by the Chief Inspector of Explosives two special licences may be granted to the Firm who may be asked to return the old licences and to revise the plans in respect of the Petrol Pump on Infantry Road in accordance with the Chief Inspector's letter at S.N.5. No fee is leviable for amendment of licences under the Bangalore Petroleum Rules.

Two draft licences submitted with fairs for favour of signature with a draft letter.

19.7.37

20/7

D.No.7256 S.N.12,

The draft and the fair have been withheld xk as the Firm have since sent two revised plans showing the location of the filling point for the underground tank etc. Para two of the draft has accordingly been deleted. It may now issue.

22.7.37

22/7

S.N.(13) ISSUE.

CORRESPONDENCE.

OFFICE OF THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION, BANGALORE.

No. 3/Pet/37 Dated 3/3/1937.

Encl: 2 sets 2 plans (4)



FROM

R. S. Milton, Esquire, I.P.,
COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE.

TO

The Secretary to the Hon'ble the Resident in Mysore,

BANGALORE.

SIR,

I have the honour to forward herewith plan and specification in duplicate received from the Burmah Shell Oil Company Madras, for a special licence for an additional underground tank and pump at Mr. Webb's Service Station on South Parade Road and recommend that the existing licence No.13 dated 4-12-1936 granted to the firm may kindly be amended to cover 1000 gallons. The capacity of the existing and proposed tanks is 500 gallons each.

For O.C. Vide page 60 of 1118-34 Vol. I.

2. The firm has sent a sum of Rs.8/- to cover the licence fee. As the fee for the amended licence is Rs.12/- out of which Rs.8/- was already collected when the licence was issued, a sum of Rs.4/- will be returned.

I have the honour to be,
Sir,
Your most obedient servant,

R. S. Milton

COMMISSIONER OF POLICE.

4/3/37.

Form D. O, 28—4,000—10-36.

COPY.

BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.
(Incorporated in England)
Madras Divisional Office,
MADRAS.

Specification to be attached to the application for the issue of special licence under Rule 6, Chapter IV, Part 2, of the Petroleum Act for the storage of Petrol in the underground tank of Petrol pump on private land at Messrs. Webb's Service Station, Bangalore.

The petroleum will be stored in a gas tight mild steel tank of 500 gallons capacity and tested up to a pressure of 3 lbs. per square inch, completely buried underground and placed on cement concrete pedestals to which it is secured by flat iron holding down straps. The tank is on private land and away from the public traffic. The tank is connected with strong metal pipes buried underground to one Hammond pump placed in the position shown in the plan herewith submitted.

AP :ST.

All communications intended for this office should be addressed to the "Chief Inspector of Explosives" and NOT to him by name.

Telegrams to "Explosives", Calcutta.

GOVERNMENT OF INDIA.

DEPARTMENT OF EXPLOSIVES.

1, COUNCIL HOUSE STREET,

Dated Calcutta, the 20th May *1937*

No. P.L.XVI-2(29)



FROM

Gordon Peace, Esqr., F.I.C.,

CHIEF INSPECTOR OF EXPLOSIVES IN INDIA.

To

The Secretary to the Honourable the

Resident in Mysore,

Bangalore

Subject:- Proposed installation of an additional underground petrol tank and pump at Mr. Webb's Service Station on South Parade Road at Bangalore.

Sir,

S.R.Z / page 4 / 17

With reference to your letter No.F.472-37/R.O.I dated the 19th March 1937, I have the honour to state that under the Petroleum Rules, 1937, which have been brought into force with effect from the 30th March 1937 licenses for all petrol pump outfits will be granted by me. The plan forwarded with your letter is therefore returned herewith with the request that the Burmah Shell Oil Storage and Distributing Co. of India Ltd. be asked to re-submit it, in triplicate, to this office with an application in form D of the rules, the necessary license fee and a certificate from the District Authority to the effect that there is no objection to their receiving a license to install the pump outfit on the proposed site.

I have the honour to be,
Sir,
Your most obedient servant,

Beli Ram

For Chief Inspector of Explosives in India

All communications should be addressed to the Secretary to the Resident in Mysore, Bangalore, by designation and not by name.

No. F.472-37
R.O. I

FROM

THE SECRETARY TO THE HON'BLE THE RESIDENT IN MYSORE.

Issued 8/3/6/37.

To

The Chief Inspector of Explosives,

C a l c u t t a.

Dated Bangalore, 3rd June *1937.*

GRANT OF SPECIAL LICENCES FOR INSTALLATION OF PETROL TANKS AND PUMPS IN THE CIVIL AND MILITARY STATION, BANGALORE.

SIR,

With reference to your letters Nos.P.L.XVI-2(33) & P.L. XVI-2(29), dated the 18th and 20th May 1937, I am directed to point out that the rules in force in the Civil and Military Station, Bangalore, are those published in the Hon'ble the Resident's Notification No.52, dated the 19th July 1909, (copy enclosed) and not the Petroleum Rules of 1937 referred to by you.

2. Under Rule 6, Chapter IV, Part II of the Bangalore Rules special licences for the possession of dangerous petroleum are granted by this Residency on your recommendation. I am to enquire whether this procedure may not be continued unti the local rules have been revised on the lines of the British Indian Petroleum Rules of 1937.

I have the honour to be,
Sir,
Your most obedient servant,

for SECRETARY TO THE RESIDENT.

BJ

DEPARTMENT.

BRANCH.

File No

Serial No

Issued 6/8/37.

Draft

Letter / Memorandum / Telegram

Class for telegrams — Ordinary / Express / Urgent* / Priority / Clear Line† — *Only for Foreign Telegrams. †Not for Foreign Telegrams.

To be issued on — Issued on

1st Reminder

2nd Reminder

3rd Reminder

Heading :

Case or Diary No.

If post copy of telegram required

Date of despatch of above

List of enclosures

(Code word for telegrams.)

No. F.472-37 R.O.I. Dated 8th June 1937. 19

From

The Asst. Secretary.

To

The Commissioner of Police,
C & M Station, Bangalore.

Grant of special licences for installation of Petrol tanks and pumps in the C & M Station, Bangalc

Sir,

With reference to your letters Nos. 6/Pet/37 & 7/Pet/37, dated the 28th & 31st May 1937, I am directed to forward a copy of a letter to the Chief Inspector of Explosives in India from this Residency No. F.472-37/R.O.I, dated the 3rd June 1937, on the subject mentioned above.

I have etc.,

Asst. Secy. to the Resdt.

5/6

S-N-7

F

5.
GIPC—S1—207 (CPS) DGP—(M-200)—27-4-32—60,000 Pads.

5/6

All communications intended for this office should be addressed to the "Chief Inspector of Explosives" and NOT to him by name.

Telegrams to "Explosives", Calcutta.

GOVERNMENT OF INDIA.

DEPARTMENT OF EXPLOSIVES.

1, COUNCIL HOUSE STREET,

Dated Calcutta, the 6th July *193* 7.

No. Mys-1 & 2

FROM

Gordon Peace, Esqr., F.I.C.,
CHIEF INSPECTOR OF EXPLOSIVES IN INDIA,

To



The Secretary to the Honourable the
Resident in Mysore,
Bangalore

Subject: Petrol pump outfits of the Burmah Shell Oil Storage and Distributing Company of India Ltd., Madras at (1) The Infantry Road and (2) The South Parade Road, Bangalore.

Sir,

S.N.2 page 12

With reference to your letter No.F.472-37/R.O.I, dated the 3rd June 1937, I have the honour to state that under the circumstances explained therein, there appears to be no objection to the grant or amendment of special licenses by the Resident as before until the Petroleum Rules in force in the civil and military station, Bangalore are revised on the lines of the British Indian Petroleum Rules, 1937.

2. The enclosure to your letter is returned herewith.

I have the honour to be,
Sir,
Your most obedient servant,

Chief Inspector of Explosives in India.

No. Mys-1 & 2 Dated the 6th July 1937.

Copy forwarded to the Burmah Shell Oil Storage and Distributing Company of India Ltd., Esplanade, Madras, for

for information and necessary action, with reference to this office letters Nos. Mys-1 and Mys-2, dated the 16th June 1937 and 17th June 1937 respectively.

2. Two Court fee stamps to the value of Rs.1/8/-, two 'no objection certificates and a license, in original, are returned herewith. The sum of Rs.17/- received with their letters Nos.M/KSPP-1937 and 1938 dated the 24th May 1937 on account of fees for the licenses will be refunded on withdrawal from the Treasury.

H.U.

2,000—3-'37.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY.

BURMAH-SHELL

OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

(INCORPORATED IN ENGLAND)

TELEPHONE No. 3964 (4 LINES.)

TELEGRAMS:—"BURMAHSHEL."

MADRAS
DIVISIONAL OFFICE

POST BOX No. 157.

BURMAH-SHELL HOUSE,
ESPLANADE,

IN REPLY PLEASE REFER TO NO. M/KSPP. 2626

MADRAS, 19th July 1937.

The Secretary to the Hon'ble the Resident in Mysore,

Bangalore.

Sir,

Petrol Pump Outfit on Infantry Road, Bangalore Cantt.

With reference to the request made to our representative Mr. E.M.Steele, we have the honour to enclose 2 copies each of plans Nos. M.1054 and M.4193 showing the location of the filling point for the underground tank, the vent pipe and the connections to the pump.

We shall be obliged if you will kindly issue us the necessary licence as soon as possible.

We have the honour to be,
Sir,
Your obedient servants,
For BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

Encl.4
AR:VNS

OFFICE OF THE RESIDENT IN MYSORE
BANGALORE.
- 1 JUL 1937
No. 7256
File No. 472-37

All communications should be addressed by designation and *not* by name.

No. F.472-37
R. O. I

Issued 23/7/37.

FROM

The ASSISTANT SECRETARY TO THE RESIDENT IN MYSORE.

To

The Commissioner of Police,
Civil and Military Station, Bangalore.

Dated Bangalore, 23rd July *1937.*

Special licences for petrol pump outfits at (1) the Infantry Road and (2) South Parade, Bangalore.

SIR,

In continuation of my letter No.F.472-37/R.O.I, dated the 8th June 1937, I am directed to forward two special licences issued in favour of the Burmah-Shell Oil Storage and Distributing Company of India, Ltd., Madras, and to request that they may kindly be transmitted to the Firm, who may be asked to return the old licences.

2. Certificates of safety referred to in Rule 11, Chapter IV, Part II, of the Petroleum Rules may kindly be obtained and forwarded to this Residency before petroleum is stored.

I have the honour to be,
Sir,
Your most obedient servant,

S/c:

Sd/- A.J.Courtney

ASSISTANT SECRETARY TO THE RESIDENT.

Copy forwarded to the Chief Inspector of Explosives in India, Calcutta, for information with reference to the correspondence ending with his letter No.Mys-1 &2, dated the 6th July 1937.

ASSISTANT SECRETARY TO THE RESIDENT.

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

No. F.472-37/R.O.I Fee Rs. 12/-

3-5-37

License is hereby granted to the Burmah-Shell Oil Storage and Distributing Company of India, Ltd., Madras,

in the licensed premises described below of 1000 for the storage of gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 ~~xxxxxxxxxxxxxxxxxxxxxxxxxxxx~~ and to the further conditions ~~attached hereto.~~ as subsequently amended and to the further conditions attached hereto.

*This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1937.

The 23rd July 1937. for OC Secretary to the ~~Government of~~ Resident in ~~xxxxxxxxxxxxxxxxxxxxxxxxxxxx~~ Mysore. ~~or an officer appointed by the Local Government in this behalf.~~

(Description of the licensed premises above referred to)

The licensed premises are situated at Infantry Road, Bangalore, and consist of a gas-tight tank of a capacity of one thousand gallons sunk underground or completely covered with earth.

*Not applicable to kerbside outfits.

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.
8.12.1937	31.12.1938	OC for Secy to the Resdt
31.12.1938	31st Dec 1939	OC for Secy to the Resdt 21/12/39

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 1000 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric-torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S7—1275 (Agency) MFP—(M-2121)—11-4-34—2,000.

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

No. F.472-37/R.O.I 13-5-37 Fee Rs. 12/-

License is hereby granted to the Burmah-Shell Oil Storage and Distributing Company of India.Ltd., Madras.

for the storage in the licensed premises described below of 1000 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 and to the further conditions attached hereto ~~xxxxxxxxxx~~ as subsequently amended and to the further conditions attached hereto.

*This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1937.

The 23rd July 19 37. for- Secretary to the ~~Government~~ Resident in Mysore. ~~or an officer appointed by the Local Government in this behalf~~

dc 19.7.37

(Description of the licensed premises above referred to)

The licensed premises are situated at Webb's Service Station on South Parade, Bangalore, and consist of a gas-tight tank of a capacity of one thousand gallons sunk underground or completely covered with earth.

*Not applicable to kerbside outfits.

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.
8-12-1937	31-12-38	dc for Secy. to the Resdt.
31st Dec 1938	31st Dec 1939	dc for Secy. to the Resdt.

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of **1000** gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S7—1275 (Agency) MFP—(M-2121)—11-4-34—2,000.

137

OFFICE OF THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION, BANGALORE.

No. 3/Pet/37. Dated 28th July 1937

FROM R. S. Milton, Esquire, I.P.

COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE.

To The Burmah Shell Oil Storage Company, Limited,
Esplanade, MADRAS.



Reference: This office letter No.3/Pet/37 dated 5-4-1937.

Two licences bearing No.F.472-37/R.O.I. (3 and 13/S/37) issued by the Secretary to the Hon'ble the Resident in Mysore, Bangalore, are sent herewith. Old licences may kindly be returned.

2. Two Certificates of safety, referred to in Rule 11 Chapter IV, Part II of the Bangalore Petroleum Rules 1909, may kindly be obtained from the Executive Engineer, Civil and Military Station, Bangalore and sent to this office, before petroleum is stored.

R. S. Milton

COMMISSIONER OF POLICE.

Copy forwarded to:-

1. The Secretary to the Hon'ble the Resident in Mysore, Bangalore, for information. The licence issued for storing petroleum at Mr. Webb's Service Station has been amended by me to cover 2 tanks of 500 gallons each, as per this office letter No.3/Pet/37 dated 2-3-1937.

2. The Inspectors of Police, B and C Divisions, for information. The licences are granted for storing petroleum at Mr. Webb's Service Station, South Parade and at A.T.A. Service Station, Infantry Road, BANGALORE.

Issued 6/8/37.

Issue 6/8

DEPARTMENT.

BRANCH.

File No.

Serial No.

Draft Letter / Memorandum / Telegram F472-37 ✓

Class for telegrams

Ordinary
Express
Urgent*
Priority
Clear Line†

*Only for Foreign Telegrams.

†Not for Foreign Telegrams.

No. R.O.I. Dated 10th August 1937.

From The Secretary.

To

The Chief Inspector of Explosives in India,
Calcutta.

To be issued on

Issued on

1st Reminder

2nd Reminder

3rd Reminder

Heading :

Case or Diary No.

If post copy of telegram required

Date of despatch of above

List of enclosures

(Code word for telegrams.)

Special licence for petrol pump outfit on the Infantry Road, Bangalore.

Sir,

In continuation of endorsement from this Residency No.F.472-37/R.O.I., dated the 23rd July 1937, I am directed to forward for retention in your office a copy each of plans Nos.M.1054 and M. 4193 received from Mxxxxx the Burmah Shell-Oil Storage and Distributing Co., Ltd., Madras.

S.N.17 page 22 (P)

I have etc.,

6/8/

for Secy to the Resident

S. R.

XGIFG—61—24-25(S & P)MVP—(M-2214)—8-8-37—50,000 Pads.

6/8/37

OFFICE OF THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION, BANGALORE.

No. 3/Pet/37 *Dated* 9/8/ 1937

FROM

R. S. Milton, Esquire, I.P.,

COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE.

To

The Burmah Shell Oil Storage Company Limited,

Esplanade, M A D R A S.

SIR,S,

Reference: This office letter No.3/Pet/37 dated 28th July 1937.

The 2 Certificates of safety, referred to, were received from Mr. R. L. Steele of your company, on 3-8-1937, in duplicate and they have been approved by me. You may now store petroleum in the tanks and pumps, referred to.

2. Old licences which have been called for may kindly be sent.



R S Milton

COMMISSIONER OF POLICE.

Copy forwarded for information, in continuation of this office endorsement No.3/Pet/37 dated 28-7-1937 to:-

1. The Secretary to the Hon'ble the Resident in Mysore, Bangalore.

(2) Two copies of certificates (One copy each), are sent herewith.

2. The Inspectors of Police, B & C Divisions.

Filed
A-J C
13/8/37

I hereby certify that the installation consisting of a petrol Kerbside pump with an underground tank for the storage of dangerous petroleum by the Burmah Shell Oil Co., Madras, on South Parade (Webb's Service Station) is satisfactory and that the enclosure walls are sufficient to ensure safety and that they comply with the - - conditions of the licence.



A.M.I.S.E.,
EXECUTIVE ENGINEER,
AND MILITARY STATION,
BANGALORE.

I hereby certify that the installation consisting of a petrol Kerbside pump with an under-ground tank for the storage of dangerous petroleum by the Burmah Shell Oil Co., Madras on Infantry road (Messrs. Moosa Sons) is satisfactory and that the enclosure walls are sufficient to ensure safety and that they comply with the conditions of the licence.

31/8/37.

A.M.I.S.E.,
EXECUTIVE ENGINEER.
CIVIL AND MILITARY STATION,
BANGALORE.

Form G. 1.—8,000—7-'37.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY.

BURMAH-SHELL

OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

(INCORPORATED IN ENGLAND)

TELEPHONE No. 3964 (4 LINES)

TELEGRAMS:—"BURMAHSHEL."

POST BOX No. 157.

BURMAH-SHELL HOUSE,
ESPLANADE,

DEPT. GENERAL

IN REPLY PLEASE REFER TO NO. F/5/G4342.

MADRAS, 12th August 1937.

The Commissioner of Police,
Civil & Military Station,
Bangalore.

Sir,

Petrol Pumps No.550 & 483 - Webb's Service Station and No.554 Infantry Road,Bangalore.

We have the honour to acknowledge receipt of your letter No.3/Pet/37 dated 9th instant from which we note that we may now put the above pumps into commission.

As desired, we return herewith the old licenses granted to us in respect of these pumps.



We have the honour to be,
Sir,
Your obedient servants,
For Burmah-Shell
Oil Storage & Distributing Co. of India Ltd.,
M Narasingam

Encl. 4 pp.
MN/PV.

3/Pet/37
No. ~~Encl. 2 Lic.~~ Dated 17/8/37

Forwarded to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, with reference to his letter No. F-472—37/R.O-I dated 23-7-37.

Commissioner of Police
C & M Station Bangalore.

16.8.

S.N.13 page 22

Filed
KS.N
17/8/37

M 482. 170 S

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

No. F.1118-34 / R.O. I Dated 21/12/34. Fee Rs. 8/-

License is hereby granted to The Burmah-Shell Oil Storage and Distributing Company of India, Ltd., Madras for the storage in the licensed premises described below of 500 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 and to the further conditions attached hereto. as subsequently amended

*This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1935

The 21st Decr. 1934.

for Secretary to the Resident in Mysore.
Secretary to the Government of
or an officer appointed by the Local
Government in this behalf.

(Description of the licensed premises above referred to)

The licensed premises are situated at Webb's Service Station on South Parade Road, Bangalore, and consist of a gas-tight tank of a capacity of five hundred gallons sunk underground or completely covered with earth.

*~~Not applicable to this license~~

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.
7th December 1935	31st December 1936.	for SECRETARY TO THE RESIDENT IN MYSORE.
13/12/37 26th November 1936.	31st December 1937.	for SECRETARY TO THE RESIDENT IN MYSORE.

CANCELLED

RESIDENT IN MYSORE AND CHIEF COMMISSIONER OF COORG

RESIDENT IN MYSORE

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 500 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police, authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S7—1275 (Agency) MFP—(M-2121)—11-4-34—2,000.

4764

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

No. F.1118-34
R.O.I

20-5-34. 18-5-34.

Fee Rs. 8/-

License is hereby granted to The Burmah-Shell Oil Storage and Distributing Company of India, Ltd.; Madras, for the storage in the licensed premises described below of 500 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 and to the further conditions attached hereto.

This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

554

This license shall continue in force till the 31st December 1935

The 17th Decr. 1934.

for SECRETARY TO THE RESIDENT IN MYSORE.
~~Secretary to the Government of~~
~~or an officer appointed by the Local~~
~~Government in this behalf.~~

(Description of the licensed premises above referred to)

The licensed premises are situated at Infantry Road, Civil and Military Station, Bangalore - - - - - - - and consist of a gas-tight tank of a capacity of five hundred gallons sunk underground or completely covered with earth.

~~*Not applicable~~

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.
7th December 1935.	31st December 1936.	for SECRETARY TO THE RESIDENT IN MYSORE.
3LS 137. 26th November 1936.	CANCELLED 31st December 1937.	for SECRETARY TO THE RESIDENT IN MYSORE.

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 500 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S7—1275 (Agency) MFP—(M-2121)—11-4-34—2,000.

Copy of letter No.M826, dated the 20th July 1937, from the Assistant Secretary to the Government of India, Department of Industries and Labour, Simla, to the Secretary to the Government of Madras, Home Department, Fort St. George.

Subject:- Petroleum Manual.

In reply to your letter No.4159F-1., dated the 29th June 1937, I am directed to say that a Manual comprising the Petroleum Act, 1934, and the rules and notifications issued thereunder together with any orders which may be issued by the Chief Inspector of Explosives under those rules is being compiled in the Office of the Chief Inspector of Explosives and will be issued as a priced publication in due course. Copies of the Manual when ready will be supplied for the use of Provincial Governments. Pending the publication of the Manual, the Petroleum and the Carbide of Calcium Rules, 1937 as well as the notifications issued under the Petroleum Act, 1934, are being printed up in a pamphlet form, copies of which will shortly be available on sale with the Manager of Publications, Civil Lines, Delhi.

A copy is forwarded to all Provincial Governments (except Madras) and to Chief Commissioners for information.



By order, etc.,

Sd/- S. K. Banerjee,

Assistant Secretary to the Govt. of India.

Copy of letter No.M826, dated the 23rd July 1937, from the Assistant Secretary to the Government of India, Department of Industries and Labour, Simla, to the Secretary to the Government of Bengal, Department of Commerce and Labour.

Subject:- Printing and supply of forms under the Petroleum Rules, 1937.

In reply to your letter No.5851-Com., dated the 6th May 1937, I am directed to say that forms of licences to be granted by the District Authorities under the Petroleum Rules, 1937, namely, Forms H, I and J, have been standardised and may be obtained by the District Authorities direct from the Manager of the Forms Press, Calcutta.

A copy is forwarded for information to all Provincial Governments and Chief Commissioners, etc.

By order, etc.,

Sd/- S. K. Banerjee,

Assistant Secretary to the Govt. of India.



Copy to R.O.

1.- V. 418/

All communications should be addressed by designation and *not* by name.

No. F.472-37
R.O. I

FROM

Issued
B 17/8/37

The ASSISTANT SECRETARY TO THE RESIDENT IN MYSORE.

To

The Manager of Publications,
Civil Lines,
Delhi.

Dated Bangalore, 17th August *1937*.

PETROLEUM MANUAL.

SIR,

I am directed to request that two copies each of the following publications may kindly be supplied to this Residency V.P.Post as soon as they become available:-

Petroleum Manual,

Petroleum and the Carbide of Calcium Rules, 1937, with notifications issued under the Petroleum Act, 1934.

I have the honour to be,

Sir,

Your most obedient servant,

Assistant Secretary to the Resident.

BJ